

Disclaimer: All content in this reference guide is presented only as of the date printed or indicated, and may be superseded by subsequent documents or for other reasons. In addition, you are responsible to ensure you are receiving the most up to date information.



Fixtures and Fittings

GENERAL INFORMATION

- All fixtures and fittings should prevent the collection of dust and growth of mold, mildew and other microorganisms
- They must be easy to maintain, and have proven durability under actual conditions of use and maintenance in healthcare facilities

CURTAINS AND BLINDS

- Curtains can easily become contaminated with microorganisms. All curtains must be able to withstand a washing process at disinfection temperatures (71°c for 25 minutes or more), or be able to withstand the washing/drying sanitizing processes that occur in an industrial or institutional setting
- Venetian horizontal blinds are not recommended as they become dusty and difficult to clean. Certain vertical blinds may be acceptable if design allows appropriate cleaning
- Blinds need to be of a construction that allows cleaning of all surfaces and functional parts

FITTINGS

- The use of lamps with fabric shades is not recommended
- If fabric shades used, the fabric must be removable and be able to withstand washing temperatures of 71°c for 3 minutes or 65°c for 10 minutes
- It is recommended to avoid lamps that have pull strings for operation, unless it is a material that is easily cleaned and will not rust
- Ceiling lights and wall mounted fixtures should have lenses and enclosed housings

VANITY TOPS

• Vanity tops must be constructed of a solid surface material, with integrated bowl and backsplash



Disclaimer: All content in this reference guide is presented only as of the date printed or indicated, and may be superseded by subsequent documents or for other reasons. In addition, you are responsible to ensure you are receiving the most up to date information.



Fixtures and Fittings (continued)

HANDRAILS AND OTHER HARDWARE

- Stainless steel remains the material of choice for handrails and other hardware, because of its durability and ease of maintenance
- Wood is acceptable if sealed, but requires ongoing maintenance

CEILING

- The ceiling must be cleanable and built to prevent the infiltration of dust from the plenum space
- The ceiling should be made of a material that does not promote the growth of microorganisms

WALLS

- Low volatile organic compound (VOC) scrub-able paint must be used
- If vinyl wall covering is selected, it should have minimal texture to facilitate thorough cleaning
- All wall coating/covering and adhesives used must have antimicrobial treatments where available

FLOORS

ifection Prevention & Control

deines

06 60

racti

S

- Sheet vinyl flooring with welded seams and an integral cove base
- Carpeting in patient care areas is strongly discouraged