

Disclaimer: All content in this reference guide is presented only as of the date printed or indicated, and may be superseded by subsequent documents or for other reasons. In addition, you are responsible to ensure you are receiving the most up to date information.



Negative Pressure Rooms

GENERAL INFORMATION

In settings where airborne precautions cannot be implemented due to limited engineering resources:

- Consult with Infection Prevention and Control to determine risk
- Place patient in private room
- Ensure windows and door remain closed, even if the patient is not in the room
- Ensure bathroom fan is off and remains off
- Patient will wear surgical grade mask(if possible) when healthcare staff and/or visitors are in the room
- Staff must wear a high efficiency N95 mask –for which they have been fit tested when in patient room
- Visitors must wear an N95 mask when in patient room. Staff must help the visitor don and *fit-check* the mask to ensure it is the right size and is worn correctly.
- Arrange for transfer of patient to a facility with a Negative Pressure Room and contact Infection Prevention and Control

The following steps should be followed when the Negative Pressure Room monitoring system indicates a failure with the system:

- Check that windows and doors are closed
- Contact Facilities Maintenance and Operations (FMO) immediately
- If FMO determines the problem cannot be fixed, follow the above policy for a facility with no Negative Pressure Room